

BID REQUEST FOR INFORMATION (RFI) FORM

SOLICITATION: VA261-14-B-0687 Medical Specialties

RFI #11– Please provide the SOILS REPORT # 9596.01 BY WALLACE KUHL & ASSOC.
DATED 12/10/2012. As called out on drawing S1.01.

[Soils report attached to this amendment.](#)

RFI#12 – Questions about windows in the specifications.

- a. Section 08 52 23 – 3 (Part 2 – Products); On site opaque painted finish- certified kiln dried. Pella specification : select softwood, water-repellent, preservative-treated with EnduraGuard triple wood protection in accordance with WDMAI.S.-4. EnduraGuard triple protection formula includes water-repellency, three active fungicides and an insecticide applied to the frame. (Kiln dried is not available.)
- b. Interior finish conflicts with next section. Section 08 52 23 – 5 (2.5 Finish); Finish exposed surfaces as follows:
 1. Fiberglass Reinforced Vinyl: White.
 2. Wood: White.

Pella does not make a fiberglass reinforced vinyl product. (It is just fiberglass.) Should we go wood/clad with prefinished white interior or unfinished pine?
- c. Window Schedule on plans A9.20: Window 34 labeled Type R casement.

Window is too large to make operable casement. We can go with a large awning but it would only be 5' tall.
- d. Should we have all of the product match the project?

FOR OFFICIAL USE ONLY

Source Selection Sensitive Information—See FAR 2.101 & 3.104

If so, then the product needs to all be wood interior aluminum clad exterior. The product that allows for shades/blinds in the glass is the Designer series.

[Please see revised window schedule.](#)